MUNICIPAL CORPORATION CHANDIGARH (Medical Officer of Health)

To

Sh. Mohinder Pathak, Health Supervisor O/o. MOH MCC.

Memo No. MOH/ Supdt .Admn /NOC /2022/ Dated: Chandigarh, the

Subject:

Issuance of Health and Sanitation certificate in respect St. Anne's Convent School, Sector 32-C, Chandigarh.

You are hereby directed to inspect the school premises St. Anne's Convent School, Sector 32-C, Chandigarh and submit report on the enclosed Performa within 03 days.

You are also directed to collect drinking water sample of the school and to deliver the same in the O/o the Sub Divisional Engineer, MCPH, Sub Division No.2, Sector-39, Chandigarh for the test. The school authorities will deposit the required water testing charges in the above said office at their own level.

Medical Officer of Health, Municipal Corporation, Chandigarh.

Endst.No.MOH/Supdt .Admn/NOC/2022/ \○ \o \o

Dated: 1 8 2022

A copy is forwarded to the following for information and necessary action:-

- The Sub Divisional Engineer, MCPH, Sub Division No.2, Sector-39, Chandigarh with the request to receive the sample of the drinking water and send copy of the report to this office.
- The Principal, of St. Anne's Convent School, Sector 32-C, Chandigarh with the request to obtain the water sample testing report from the office of S.D.E, MCPH, Sub Division no.2, Sector-39(water-works) Chandigarh after depositing the required fee.

Medical Officer of Health, Municipal Corporation, Chandigarh

MUNICIPAL CORPORATION CHANDIGARH (Medical Officer of Health)

(SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE)

No. MOH/Supdt.Admn/2022/12642

Dated:-09/9/2011

It is certified that an inspection team headed by <u>Sh. Mohinder Pathak</u>, <u>Health Supervisor</u> from <u>Office of Medical Officer of Health, Municipal Corporation</u> <u>Chandigarh inspected the St. Anne's Convent School, Sector 32-C</u>, Chandigarh, on <u>26.08.2022</u> and mentioned in inspection report that St. Anne's Convent School, Sector 32-C Chandigarh, is maintaining the hygienic sanitation condition in the premises as per the norms prescribed by the Central/State/U.T Govt. This certificate is issued with the prior approval of competent authority, Municipal Corporation Chandigarh.

The above Certificate is valid for a period of One-year w.e.f 15-07-2022 (i.e.Water Sampling Date).

Medical Officer of Health Municipal Corporation Chandigarh

To,

St. Anne's Convent School, Sector 32-C, Chandigarh,



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works, Sector 39.

TEST - REPORT

Not for legal use

Ref. No. & Date	1 -	No. SACS/01/2022-23/10 dated 05.07.2022
Issued to	19	The Principal, St. Anne's Convent School, Sector – 32 - C, Chandigarh.
Quantity of sample Date of Collection Client reference Packing of sample Source of sample	: :- :- :- :- :- :-	Approximate 1200 ml. 12.07.2022 Sample collected by Laboratory Staff. Sample filled in P.P. and Glass Bottle. from School tap of St. Anne's Convent School, Sector – 32 - C, Chandigarh.

S. No. Examination	Quality Standard	Units	Results
1. Turbidity	<1.0	N.T.U	0.8
2. pH	7.0-8.5		7.85
3. Residual Chlorine	0.2 - 0.4	mg/L	0.2
4. Total Alkalinity (as CaCO ₃)	200	-do-	76
5. Total Hardness (as CaCO ₃)	200	-do-	68
6. Chlorides (as C1)	200	-do-	04
7. Free & Saline Ammonia	Nil	-do-	Nil
8. Total Dissolved Solids	500	-do-	120
9 M.P.N. of Coliform Bacilli per 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No.07/2022-23/084229, dated 11.07.2022, Amount Rs.3300/-.

Note: Water is fit for drinking.

Lab.	No.	MCPHL/22/	3	185
		5 07 2022		

MCPH Laboratory, Chandigarh

Sub Divisional Engineer, M.C.P.H. Sub Division No. 2, Chandigarh

Endst No. MCPHL/22/

Dated

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh for information please.

MCPH Laboratory Chandigarh

Sub Divisional Engineer, M.C.P.H. Sub Division No. 2,

Chandigarh